

§ 254.43

(h) The Regional Supervisor may require changes in the frequency or location of the required exercises, equipment to be deployed and operated, or deployment procedures or strategies. The Regional Supervisor may evaluate the results of the exercises and advise the owner or operator of any needed changes in response equipment, procedures, or strategies.

(i) Compliance with the National Preparedness for Response Exercise Program (PREP) Guidelines will satisfy the exercise requirements of this section. Copies of the PREP document may be obtained from the Regional Supervisor.

§ 254.43 Maintenance and periodic inspection of response equipment.

(a) You must ensure that the response equipment listed in your response plan is inspected at least monthly and is maintained, as necessary, to ensure optimal performance.

(b) You must ensure that records of the inspections and the maintenance activities are kept for at least 2 years and are made available to any authorized MMS representative upon request.

§ 254.44 Calculating response equipment effective daily recovery capacities.

(a) You are required by § 254.26(d)(1) to calculate the effective daily recovery capacity of the response equipment identified in your response plan that you would use to contain and recover your worst case discharge. You must calculate the effective daily recovery capacity of the equipment by multiplying the manufacturer's rated throughput capacity over a 24-hour period by 20 percent. This 20 percent efficiency factor takes into account the limitations of the recovery operations due to available daylight, sea state, temperature, viscosity, and emulsification of the oil being recovered. You must use this calculated rate to determine if you have sufficient recovery capacity to respond to your worst case discharge scenario.

(b) If you want to use a different efficiency factor for specific oil recovery devices, you must submit evidence to substantiate that efficiency factor. Adequate evidence includes verified

30 CFR Ch. II (7-1-00 Edition)

performance data measured during actual spills or test data gathered according to the provisions of § 254.45 (b) and (c).

§ 254.45 Verifying the capabilities of your response equipment.

(a) The Regional Supervisor may require performance testing of any spill-response equipment listed in your response plan to verify its capabilities if the equipment:

- (1) Has been modified;
- (2) Has been damaged and repaired; or
- (3) Has a claimed effective daily recovery capacity that is inconsistent with data otherwise available to MMS.

(b) You must conduct any required performance testing of booms in accordance with MMS-approved test criteria. You may use the document "Test Protocol for the Evaluation of Oil-Spill Containment Booms," available from MMS, for guidance. Performance testing of skimmers also must be conducted in accordance with MMS approved test criteria. You may use the document "Suggested Test Protocol for the Evaluation of Oil Spill Skimmers for the OCS," available from MMS, for guidance.

(c) You are responsible for any required testing of equipment performance and for the accuracy of the information submitted.

§ 254.46 Whom do I notify if an oil spill occurs?

(a) You must immediately notify the National Response Center (1-800-424-8802) if you observe:

- (1) An oil spill from your facility;
- (2) An oil spill from another offshore facility; or
- (3) An offshore spill of unknown origin.

(b) In the event of a spill of 1 barrel or more from your facility, you must orally notify the Regional Supervisor without delay. You also must report spills from your facility of unknown size but thought to be 1 barrel or more.

(1) If a spill from your facility not originally reported to the Regional Supervisor is subsequently found to be 1 barrel or more, you must then report it without delay.

(2) You must file a written followup report for any spill from your facility